

Collection Site of Water Sample

Name Jeff Pinyoun
Address XXXX Cedarwood Court
Clayton NC 27520
E mail Address: jeffpinyoun@yahoo.com

Permit # **Self** Comments:

Collected by: Self
Date Collected: 11/8/2014
Time Collected: 1:30 PM
Reporting Date: 11/11/2014
Analyzed by: K. Trossman
Lab Number: 26.13

Results:

Total Coliform	Absent
E. coliform (fecal)	Absent

Other Info:

EPA Limits for Safe Drinking Water

Absent

Absent

Reported by:
Kimberly Trossman
Kimberly Trossman
Environmental Chemist

Certification #37503

Jeff Pinyoun
 Collection Address: XXXX Cedarwood Court Clayton NC 27520
 Additional Information: **Mail to: 10728 Wilmore Dr., Raleigh 27614**

Collection Date: 11/8/2014
Collection Time: 1:30 PM
Collected by: Self
Lab Number: 26.13

Parameter	Result	Units	Limits for Drinking Water *
Lead, flushed	0.007	mg/L	0.015 mg/L
Nitrate	1.16	mg/L	10 mg/L
Nitrite	<0.1	mg/L	1 mg/L
Alkalinity	49	mg CaCO ₃ /L	No established limit
Silver	<0.01	mg/L	0.1 mg/L
Arsenic	<0.005	mg/L	0.010 mg/L
Barium	<0.05	mg/L	2 mg/L
Ca	22.8	mg/L	No established limit
Cd	<0.001	mg/L	0.005 mg/L
Chloride	10.8	mg/L	250 mg/L
Chromium	<0.02	mg/L	0.100 mg/L
Copper	<0.05	mg/L	1.3 mg/L
Fluoride	1.06	mg/L	Regulatory 4 mg/L Secondary 2 mg/l Health 7 mg/L
Iron	0.52	mg/L	Aesthetic 0.3 mg/L
Hardness	63	mg CaCO ₃ /L	No established limit
Magnesium	1.5	mg/L	No established limit
Manganese	<0.01	mg/L	Health 1.61 mg/L Aesthetic 0.05 mg/L
pH	7.62	SI	6.5-8.5
Selenium	<0.005	mg/L	0.05 mg/L
Sodium	25.5	mg/L	No established limit
Zinc	1.01	mg/L	5 mg/L
Mercury	<0.0002	mg/L	0.002 mg/L

Report Date: 11/11/2014
 Submitted by: Kimberly Trossman

* Limits are EPA Safe Drinking Water Primary and/or Secondary Standards.